

Board of Boiler and Pressure Vessel Rules

Meeting Minutes for

May 26th, 2011

Division Fire Safety

205 Jefferson, 13th Floor

Jefferson City, Missouri 65101

Board Members Present

Wayne Mueller

Vergil Belfi

Mark Lester

Bob Weber

Bassem Armaly

Board Members Absent

Dorothy Creager

Visitors

Bill Manes-Travelers

Rick Heard-KCPL

John Bryan-Air Products

Jim Goss-Pioneer Industrial Co.

Jim Pratt-Cincinnati Ins.

Rich Scheerer-FM Global

Brandon Rhodes-Airgas Mid America

Staff Present

Gary Scibner-Chief Inspector, MO

Dawn Urban-Office Support Asst.

Joe Brockman-State Inspector

Vance Adams-State Inspector

Gene Reece-State Inspector

Dwaine Dierksen-State Inspector

I. Open & Welcome

Meeting was called to order by Chairman Wayne Mueller at 9:00 a.m. on May 26th, 2011 at the Division of Fire Safety. Introduction of the Board Members, visitors and staff was completed.

II. Approval of the February 10th, 2011 Meeting Minutes

Motion was made by Vergil Belfi to approve the meeting minutes as written. Bob Weber seconded the motion. Motion passed unanimously to approve the February 10th, 2011 meeting minutes.

III. Approval of the May 26th, 2011 Agenda

Motion was made by Vergil Belfi to approve the agenda as written. Bob Weber seconded the motion. Motion passed unanimously to approve the agenda.

IV. Chief's Report

- Gary completed one Joint Review since the last Boiler Board Meeting.
- Chief attended the CSD-1 meeting in Portland, OR.
- Chief attended the NB meeting in Las Vegas.
- State Inspector Fred Evensen passed his State Commission exam.

V. Secretary's Fiscal Summary Report

Fiscal Year 2011

Amount

Total Revenues Deposited to Date:

\$543,971.70

Fiscal Year 2011

Total Unit Expense & Equipment to Date:

\$50,697

Payroll for Boiler Unit Personnel to Date:

\$274,581

VI. Old Business

VII. New Business

11-04-Air Products requesting a variance on the pressure relief devices on their high pressure storage vessels. Motion was made by Bob Weber to approve the variance with the following stipulation-written administrative controls must be approved by the chief

inspector and put in place to address all intervening valves between the vessels and safety relief valve. Mark Lester seconded the motion. Motion passed unanimously to grant the variance with stipulations. **(Item Closed, Letter Sent)**

11-05-Park Towers requested a variance on their boiler clearances. Bassem Armaly made a motion to approve the variance. Vergil Belfi seconded the motion. Motion passed unanimously to approve the variance. **(Item Closed, Letter Sent)**

11-06-Airgas requested a variance of rules for pressure vessel storage and filling at Nordyne Company in Poplar Bluff, MO. This request is to allow on site use and filling of DOT3AAX-2845 high pressure storage tubes in lieu of an ASME pressure vessel. Vergil Belfi made a motion to approve the variance with the following stipulation-ASME safety relieving devices on manifold and you must provide the state with records of acoustic emissions test results every five years. Bob Weber seconded the motion. Motion passed unanimously to grant the variance with stipulations. **(Item Closed, Letter Sent)**

11-07-Novus International Inc. requested a variance to allow air filter to remain in suction of combustion air fan. Vergil Belfi made a motion to approve the variance with the following stipulation-Must have a CO2 Detector in the boiler room with a remote alarm. Bob Weber seconded the motion. Motion passed unanimously to approve the variance with stipulations. **(Item Closed, Letter Sent)**

11-07(2)-Motion was made by Bassem Armaly to grant the Chief Inspector the authority to grant any further requests of variances as such **11-07**. Bob Weber seconded the motion. Motion passed unanimously to allow the Chief Inspector the authority to grant further request of variances as item **11-07**.

11-08-Land O'Lakes Purina Feed requested a variance on the ceiling height above their boiler. Bassem Armaly made a motion to approve the variance. Mark Lester seconded the motion. Motion passed unanimously to approve the variance. **(Item Closed, Letter Sent)**

VIII. Next Meeting

The next Board of Boiler & Pressure Vessel Rules Meeting will be held on August 11th, 2011 at 9:00 a.m. at the Division of Fire Safety, 205 Jefferson St. Jefferson City, Missouri 65102.

IX. Adjournment

Motion was made by Vergil Belfi to adjourn. Mark Lester seconded the motion. Motion passed unanimously to adjourn.

